

J. B. Moore\*

**Steady-state response in the parameter plane\*\***UDC 62.50  
IFAC IA 2

This paper considers the adjustment of parameters in linear control systems to meet both steady-state and transient response specifications. A graphical method using parameter plane techniques is presented whereby the steady-state error may be minimized while being constrained by the transient response requirements. Another method is proposed whereby, for a specified steady-state response, the transient response is given in evidence as a function of three system parameters. The procedures are illustrated by examples for both continuous and sampled-data multi-loop control systems.

The problem of linear control system design can be interpreted as the adjustment of the system parameters to meet both steady-state and transient response requirements. The Šiljak parameter plane method [1-5] gives in evidence the pole-zero locations of a system closed-loop transfer function in terms of two system parameters. In the application of the method, the transient response requirements are translated into constraints imposed on the pole-zero configuration of the system transfer function. The steady-state response on the other hand, can be specified by the error constants. As shown in this paper, the error constants are functions of adjustable system parameters and may be introduced into the parameter plane. This enables the steady-state and transient response to be considered simultaneously in a control system design.

Two graphical design procedures are presented. In the first, error constant contours are plotted on the parameter plane enabling the steady-state error to be minimized subject to constraints imposed on the system pole-zero locations. In the second procedure, the transient response is studied on the parameter plane for a specified error constant, and is given in evidence as a function of three system parameters.

The parameter plane curves are readily plotted using a digital computer, and so the methods are presented as a practical approach to the design of linear control systems. In the following sections, the parameter plane approach and the error constant definitions are reviewed for reference, the two design procedures are developed, and examples illustrating the procedures are discussed for both continuous and sampled-data multi-loop control systems.

**Summary of the parameter plane method**

The characteristic equation considered in the design of linear continuous systems is

$$f(s) = \sum_{k=0}^m a_k s^k = 0 \quad (1)$$

The complex roots of equation (1) are expressed in terms of their damping ratio  $\zeta$  and their natural frequency  $\omega_n$

$$s = -\omega_n \zeta \pm j\omega_n \sqrt{1 - \zeta^2} \quad (2)$$

Substituting equation (2) into equation (1) results in two equations which may be manipulated and conveniently expressed in terms of the Chebyshev functions as follows

$$\sum_{k=0}^m (-1)^k a_k \omega_n^k U_k(\zeta) = 0, \quad (5)$$

$$\sum_{k=0}^m (-1)^k a_k \omega_n^k U_{k-1}(\zeta) = 0$$

The Chebyshev functions  $U_k(\zeta)$  may be calculated from the recurrence relationship

$$U_{k+1}(\zeta) - 2\zeta U_k(\zeta) + U_{k-1}(\zeta) = 0 \quad (4)$$

where  $U_0(\zeta) = 1$  and  $U_1(\zeta) = \zeta$ .

The coefficients of the characteristic equation are expressed as

$$a_k = b_k \alpha + c_k \beta + h_k \alpha \beta + d_k \quad (5)$$

where  $b_k$ ,  $c_k$ ,  $h_k$ , and  $d_k$  are functions of the fixed parameters of the system and are therefore of known numerical value, and  $\alpha$  and  $\beta$  are the two system parameters to be selected in the design.

The substitution of equation (5) into equation (5) results in two equations

$$B_1 \alpha + C_1 \beta + H_1 \alpha \beta + D_1 = 0, \quad (6)$$

$$B_2 \alpha + C_2 \beta + H_2 \alpha \beta + D_2 = 0$$

where

$$B_1 = \sum_{k=0}^m (-1)^k b_k \omega_n^k U_{k-1}(\zeta), \quad B_2 = \sum_{k=0}^m (-1)^k b_k \omega_n^k U_k(\zeta),$$

$$C_1 = \sum_{k=0}^m (-1)^k c_k \omega_n^k U_{k-1}(\zeta), \quad C_2 = \sum_{k=0}^m (-1)^k c_k \omega_n^k U_k(\zeta), \quad (7)$$

$$H_1 = \sum_{k=0}^m (-1)^k h_k \omega_n^k U_{k-1}(\zeta), \quad H_2 = \sum_{k=0}^m (-1)^k h_k \omega_n^k U_k(\zeta),$$

$$D_1 = \sum_{k=0}^m (-1)^k d_k \omega_n^k U_{k-1}(\zeta), \quad D_2 = \sum_{k=0}^m (-1)^k d_k \omega_n^k U_k(\zeta)$$

By solving equations (6) for  $\alpha$  and  $\beta$ , the  $\zeta$  and  $\omega_n$  curves are plotted in the  $\alpha\beta$ -plane. The complex roots of equation (1) are then determined by interpolating between these curves.

When the roots of the characteristic equation are real, i.e.,  $s = -\sigma$ , equation (1) may be expressed as

$$\alpha \sum_{k=0}^m b_k (-\sigma)^k + \beta \sum_{k=0}^m c_k (-\sigma)^k + \alpha \beta \sum_{k=0}^m h_k (-\sigma)^k +$$

\* J. B. Moore is with the Department of Electrical Engineering, University of Santa Clara, Santa Clara, California.

\*\* The research reported herein was supported by the National Aeronautics and Space Administration under Contract No. NAS 2-2609.

$$\sum_{k=0}^m d_k (\sigma - \rho)^k = 0 \tag{8}$$

Constant  $\sigma$  lines are readily plotted in the parameter plane using equation (8). Therefore, both real and complex roots are given in evidence as functions of  $\alpha$  and  $\beta$ .




Fig. 1. System block diagram

For sampled-data systems, z-transform theory is applied and the characteristic equation is expressed as follows

$$f(z) = \sum_{k=0}^m a_k z^k - 1 = 0 \tag{9}$$

where

$$z = e^{sT} \tag{10}$$

$T$  being the sampling period.

The complex roots of  $f(z) = 0$  are expressed in terms of the z-plane damping ratio  $\zeta_z$  and the z-plane natural frequency  $\omega_z$

$$z = \omega_z / \cos^{-1}(\zeta) = \omega_z \zeta \pm j \omega_z \sqrt{1 - \zeta^2} \tag{11}$$

The real roots of  $f(z)$  are given by

$$z = -\sigma_z \tag{12}$$

The form of these equations is similar to that given for continuous systems. Equations (6), (7), and (8) may therefore be used to map the parameter plane in terms of  $\zeta$  and  $\omega_n$  for a sampled-data system by making the following substitutions derived from equations (2), (10), (11) and (12):

$$\begin{aligned} & \exp(-\omega_n z T) \text{ for } \omega_n \\ & - \cos(\omega_n T \sqrt{1 - \zeta^2}) \text{ for } \zeta, \\ & \exp(-\sigma T) \text{ for } \sigma \end{aligned} \tag{15}$$

The only portion of the s-plane considered is the primary strip; i.e.,  $|\omega \sqrt{1 - \zeta^2}| \leq \pi/T$ .

**Error constants**

The symbol  $K_e$  will be used to represent either the position error constant  $K_p$ , the velocity error constant  $K_v$ , or the acceleration constant  $K_a$ . The error constants are defined for the continuous system and sampled-data system as follows:

<i>For continuous systems</i>	<i>For sampled-data systems</i>
$K_p = \lim_{s \rightarrow 0} G(s)$ ,	$K_p = \lim_{z \rightarrow 1} G(z)$ .
$K_v = \lim_{s \rightarrow 0} sG(s)$ ,	$K_v = \lim_{z \rightarrow 1} (1 - z) G(z)/T$ .
$K_a = \lim_{s \rightarrow 0} s^2 G(s)$ ,	$K_a = \lim_{z \rightarrow 1} (1 - z)^2 G(z)/T^2$ ,

(14)

where  $G(s)$  and  $G(z)$  are the system open-loop transfer functions. The steady-state errors for a unit step

function, ramp or parabolic input to the system are given by  $1/(1 + K_p)$ ,  $1/K_v$ ,  $1/K_a$ , respectively.

The next section considers the minimization of a system steady-state error subject to the transient response specifications. The analytical maximization of  $K_e$  subject to relative stability constraints is considered and then the graphical maximization of  $K_e$  on the parameter plane subject to the transient response specifications is introduced and illustrated by examples.

**Minimization of steady-state error on the  $\alpha\beta$ -plane**

Consider the error constant  $K_e$ , expressed as a function of the two system parameters  $\alpha$  and  $\beta$ :

$$K_e = K_e(\alpha, \beta) \tag{15}$$

The solutions of the simultaneous equations

$$\frac{\partial K_e}{\partial \alpha} = 0 \quad \text{and} \quad \frac{\partial K_e}{\partial \beta} = 0 \tag{16}$$

which satisfy the conditions

$$\frac{\partial^2 K_e}{\partial \alpha^2} < 0, \quad \begin{vmatrix} \frac{\partial^2 K_e}{\partial \alpha \partial \beta} \\ \frac{\partial^2 K_e}{\partial \alpha^2} \end{vmatrix} = \frac{\partial^2 K_e}{\partial \alpha^2} \cdot \frac{\partial^2 K_e}{\partial \beta^2} < 0 \tag{17}$$

are the maxima values of  $K_e$  on the  $\alpha\beta$ -plane. The absolute maximum  $K_e$  is therefore readily determined. However, the transient response associated with this value of  $K_e$  is usually not acceptable. To ensure a more acceptable transient response, relative stability constraints may be included into the analytical derivation as follows.

Consider the maximization of  $K_e$  subject to the constraints that all the roots of the characteristic equation have damping ratios  $\zeta$  greater than or equal to the prescribed value  $\zeta_0$ ; i.e.,  $\zeta \geq \zeta_0$ . The region of interest in the  $\alpha\beta$ -plane is therefore bounded by the  $\zeta = \zeta_0$  curve. If the maximum  $K_e$  for this region occurs inside the boundary, then its value may be determined from equations (16) and (17). If the maximum  $K_e$  for the region does not occur inside the boundary, then it occurs on the boundary itself and its value may be calculated from the following equation

$$\left( \frac{\partial K_e}{\partial \omega_n} \right)_{\zeta = \zeta_0} = \left( \frac{\partial K_e}{\partial \alpha} \cdot \frac{\partial \alpha}{\partial \omega_n} + \frac{\partial K_e}{\partial \beta} \cdot \frac{\partial \beta}{\partial \omega_n} \right)_{\zeta = \zeta_0} = 0 \tag{18}$$

and the condition  $\left( \frac{\partial^2 K_e}{\partial \omega_n^2} \right)_{\zeta = \zeta_0} < 0$




Fig. 2. Maximization of the error constant

The partial derivatives  $\frac{\partial \alpha}{\partial \omega_n}$  and  $\frac{\partial \beta}{\partial \omega_n}$  may be obtained from equations (6) and (7) in a straightforward manner, but the calculation of the maxima values of  $K_v$  may become tedious as the roots of a high degree algebraic equation in  $\omega_n$  must be found and examined.

The constraints  $\zeta \geq \zeta_0$  are not sufficient to ensure an acceptable transient response, but to include further constraints analytically would be difficult. Using the parameter plane, however, the problem of adjusting the system parameters to give the best compromise between steady-state and transient response may be attempted by plotting contours of constant  $K_v$  on the  $\alpha\beta$ -plane. The curves are interpreted as in the following examples.

Consider the system of Fig. 4 where

$$G_1(s) = K_1 \frac{(s+1)}{(s+0.2)}, \quad G_2(s) = \frac{K_2}{s(s^2+0.8s+1)}$$

$$G_{-1}(s) = K_{-1}s, \quad G_{-2} = K_{-2}s^2$$

The system characteristic equation is

$$s^4 + (a+1)s^3 + (0.2a + \beta + 1.16)s^2 + (0.2\beta + \gamma + 0.2)s + \gamma = 0 \quad (19)$$

where  $a = K_2K_{-2}$  and  $\beta = K_2K_{-1}$  and  $\gamma = K_1K_2$

The error constant  $K_v$  can be expressed as

$$K_v = \frac{\gamma}{0.2(1+\beta)} \quad (20)$$

Fig. 2 gives the parameter plane curves for the condition  $\gamma = 20$ . By plotting just a few  $\zeta$  lines, the region of interest in the  $\alpha\beta$ -plane is evident. It is seen that perhaps the best compromise between the steady-state and the transient response for a specified  $\zeta_0$  is not at the point of maximum  $K_v$  given by analytical methods (e.g.,  $M_1$  for  $\zeta = 0.5$ ;  $M_2$  for  $\zeta_0 = 0.5$ ), but in the region where the real axis characteristic roots are conveniently located (e.g.,  $M_3$  for  $\zeta_0 = 0.5$ ).




Fig. 5. System block diagram

In a system design, the transient response may be calculated at points of interest in the parameter plane. The roots of the characteristic equation for these points may be found approximately by interpolation from the parameter plane or, more accurately, by an iterative method. In the example, the characteristic equations roots  $M_1, M_2, M_3$  are given as follows:

$M_1$	$M_2$	$M_3$
$\zeta_1 = 0.5$	$\zeta_1 = 0.5$	$\zeta_1 = 0.5$
$\omega_{n1} = 2.25$	$\omega_{n1} = 2.25$	$\omega_{n1} = 1.25$
$\zeta_2 = 0.69$	$\zeta_2 = 0.86$	$\sigma_1 = 1.7$
$\omega_{n2} = 1.99$	$\omega_{n2} = 1.98$	$\sigma_2 = 7.4$

For the regions  $M_1$  and  $M_2$ , the two pairs of complex poles are now given explicitly, and it is seen that for the regions  $M_1$  and  $M_2$  the transient response is unac-

ceptable. The response for the region  $M_3$  may be calculated using Laplace transform methods and a design compromise achieved. Further, the  $\alpha\beta$ -plane curves may be replotted for different specified parameters in order to explore the possibilities of an improved design. Usually, when a time constant is considered as the one parameter  $\alpha$ , and a gain as the other parameter  $\beta$ ,  $\alpha\beta$ -product terms appear in the characteristic equation and the results of reference 2 are used to plot the parameter plane.



Fig. 4. Maximization of  $K_v$  in a sampled-data system

Consider as a second example the sampled-data system given in Fig. 5 [5] where the sampling period  $T$  is one second and

$$G_1(s) = \frac{1 - e^{-Ts}}{s}, \quad G_2(s) = \frac{K_2}{s + 0.19}$$

$$G_3(s) = \frac{0.741 K_1}{s(s + 5.9)}, \quad G_{-1}(s) = \frac{1.9 K_{-1}s}{s + 1.9}$$

the z-transforms of interest are

$$G_1G_2(z) = K_2 \frac{0.91}{z - 0.827}, \quad G_3G_4(z) = K_4 \frac{0.142z + 0.186}{(z - 1)(z - 0.02)}$$

$$G_3G_4G_{-1}(z) = K_1K_{-1} \frac{0.159z + 0.019}{(z - 0.15)(z - 0.02)}$$

The characteristic equation may be written as follows:

$$f(z) = z^4 + (0.189a - 2)z^3 + (-0.257a + 0.092\beta + 1.14)z^2 + (0.081a + 0.014\beta - 0.146)z + (0.01a - 0.004\beta - 0.002) = 0 \quad (21)$$

where  $a = K_1K_{-1}$  and  $\beta = K_2K_4$

The error constant  $K_v$  is given from the definition (14) as

$$K_v = \frac{1.765\beta}{1 + 0.19a} \quad (22)$$

The maximum  $K_v$  for a specified settling time is given in evidence in Fig. 4. For a settling time  $\omega_n\tau = 0.1$ ; i.e.,  $\omega_n = 0.905$ , the maximum  $K_v$  occurs at the point  $M$  in Fig. 4 (i.e.,  $K_v = 2.7$ ). It is to be noted that the steady-state errors are given only at the sampling instants.

The parameter plane in these examples may be plotted with the error constant as one of the axis. All

that is required is that the equation for  $K_v$  be incorporated into the computer program which calculates the various parameter plane curves. The parameter plane method is not limited to the damping ratio ( $\zeta$ ) and the settling time ( $\omega_n \tau$ ) contours as illustrated in the above examples, but any convenient contour may be plotted and therefore other stability constraints may be considered in a system design.

The error constant for a system may be specified, in which case the transient response may be investigated as a function of  $\alpha, \beta$ , and a third parameter  $\gamma$  on a single parameter plane diagram. This case is now considered.




Fig. 5. Parameter plane diagram for a specified  $K_v$ .

### Three-parameter problem

If the error constant  $K_v$  is specified, the parameter plane method may be extended to study the characteristic equation root locations as a function of three parameters. The effect of adjusting the two parameters  $\alpha$  and  $\beta$  may be studied on the  $\alpha\beta$ -plane, and for each point a third parameter  $\gamma$  is then given as a known function of  $\alpha, \beta$ , and  $K_v$ . An example from the preceding section is used to illustrate the design procedure. For the system of Fig. 1, if  $K_v$  is specified, the characteristic equation may be expressed in terms of  $\alpha$  and  $\beta$  by eliminating the third parameter  $\gamma$  from equations (19) and (20). For  $K_v = 10$ ,  $\gamma = 2(1 + \beta)$  and

$$s^4 + (\alpha + 1)s^3 + (0.2\alpha + \beta + 1.16)s^2 + (2.2\beta + 2.2)s + (2\beta + 2) = 0 \quad (25)$$

From the parameter plane plot of equation 25 in Fig. 5, it is seen that  $\alpha$  and  $\beta$  may be selected to give a good transient response and  $\gamma$  may then be calculated for trial points and the system designed (e.g., for  $M, \zeta = 0.5$ ,  $\omega_n = 2.5$ ,  $\sigma_1 = 1.5$ ,  $\sigma_2 = 2.1$ ). This approach to the simultaneous consideration of steady-state and transient response enables the designer to examine readily the effectiveness of various compensating networks. All that is required is the interpretation of the parameter plane diagrams corresponding to each proposed system.

### Conclusions

It has been shown that the steady-state and transient response may be considered simultaneously in a linear control system design using the parameter plane. Two procedures were developed and illustrated by examples of both continuous and sampled-data multi-loop control systems. In the first procedure, the steady-state error was minimized subject to the transient response requirements; while in the second procedure, the effects of three system parameters on the transient response were given in evidence for a specified error constant.

The scope of the problem discussed in this paper is but one aspect of the more general problem of introducing specifications and constraints into the analytical or graphical design procedures in order to give in evidence more relevant information for the system design. The work of this paper may be extended to include more directly the transient response specifications into the design procedures such that the effect of more system parameters may be considered.

### REFERENCES

- [1] D. D. Siljak, *Analysis and Synthesis of Feedback Control Systems in the Parameter Plane - Part I, Linear Continuous Systems*, IEEE Trans. on Applications and Industry, Vol. 85, No. 75, Nov., 1964; pp 449-458.
- [2] D. D. Siljak, *An Extension of the Parameter Plane Method* (Published in the same issue).
- [3] D. D. Siljak, *Analysis and Synthesis of Feedback Control Systems in the Parameter Plane - Part II, Sampled-Data Systems*, IEEE Trans. on Applications and Industry, Vol. 85, No. 75, Nov. 1964; pp 458-466.

**Stacionarni odziv u parametarskoj ravni.** Uradu je primenjena grafička parametarska metoda za sintezu linearnih sistema automatskog upravljanja sa minimalnom greškom ustaljenog stanja, a uz zadovoljavajuću relativnu stabilnost. U radu se također predlaže da se u parametarskoj ravni crtaju familije krivih u odnosu na konstante grešaka ustaljenog stanja kao trećeg parametra. Postupci su ilustrovani na primerima kontinualnih i impulsnih sistema automatskog upravljanja. Pošto je ukratko izložena parametarska metoda, u radu se predlaže jedno proširenje ove metode za sintezu sistema automatskog upravljanja. Parametarska metoda omogućava, naime, sintezu sistema automatskog upravljanja željenih dinamičkih osobina, dok se greška ustaljenog stanja može proveriti tek kada se sinteza sistema sprovede. Izražavajući greške ustaljenog stanja preko konstanti grešaka, u radu se razraduje postupak, koji omogućava da se tokom sinteze istovremeno vodi računa i o dinamičkim osobinama sistema i o greški ustaljenog stanja, pa prema tome i minimizaciji greške ustaljenog stanja pri zadatim dinamičkim osobinama sistema. Postupak je primenljiv kako za kontinualne tako i za impulsne sisteme automatskog upravljanja i nije ograničen u pogledu njihove strukture. Postupak je ilustrovan sa dva primera.

**Статическая характеристика в плоскости параметров.** Предлагаемая читателю статья рассматривает вопрос настройки параметров линейных систем автоматического управления для выполнения требований возлагаемых на статическую и динамическую характеристики. Предлагается графический метод использующий техники плоскости параметров, который позволяет минимизировать статическую ошибку, одновременно беря в учет требования к динамической характеристике. Дается тоже другой метод, который, при заданной статической характеристике, определяет динамическую характеристику, как функцию трех параметров. Эти методы иллюстрируются примерами непрерывных и дискретных много-петлевых систем автоматического управления.